DRY TYPE TRANSFORMER SPECIFICATION

TRANSFORMER SPECIFICATION

VOLTAGE

BIL

TAPS - FCAN

TAPS - FCBN

CONDUCTOR

INSULATION CLASS

AVG. SOUND LEVEL

MIN EFFICIENCY

ELECTROSTATIC

IMPEDANCE (@ 170°C)

WINDINGS

SHIELD EST. WEIGHT

	PRIMARY SECONDARY					
K-FACTOR	1					
FREQUENCY	60Hz					
PHASES	1					
TEMPERATURE RISE	150°C					
COOLING	ANN					
RATING	50kVA					

2 x 2.5%

10kV

TERMINALS AND CABLE LUGS

	PRIMARY	SECONDARY			
LOCATION	FRONT	FRONT			
LINE LUGS (/PH)	1 OF 2/0-6 AWG	1 OF 300 MCM-6 AWG			
NEUTRAL LUGS	N/A	N/A			
GROUND LUG	2/0-6 AWG LUG ON ENCLOSURE BASE				

WIRING / CONNECTIONS ONDAR PRIMARY: H1-H2 120/240V 480V 2 x 2.5%

-

10kV

ALUMINUM

POLYESTER RESIN DIPPED

220°C

3.5% - 5.0%

98.3% @ 35% LOAD, 75°C

45dBA


NONE

315 lbs [143kg]

	12						
VOLTAGE	% TAP	JUMPERS TO:					
504	105.0%	1-1					
492	102.5%	2-2					
480	30 100.0% 3-3						
468	97.5% 4-4						
456	95.0% 5-5						
SECONDARY: X1-X2-X3-X4							
VOLTAGE	INTERCONNECT	CONNECT LOAD TO					
240	240 X2 to X3 X1-X4						
120	X1 to X3 & X2 to X4	X1/X3 - X2/X4					
240/120	X2 to X3	X1-X2-X4 (X2 is a neutral)					

1)Location of nameplate and labels for Canada

2)Location of nameplate and labels for USA




*FOR PROPER VENTILATION FOR FLOOR INSTALLATION KEEP AT LEAST 6 INCHES FROM ADJACENT WALLS

REV	REMARKS	BY	DATE	PRELIMINARY DRAWING	PRODUCT		GENE	RAL PURPO	SE ISOLATION TRANSFORMER
				THIS DRAWING MAY NOT TRULY REFLECT OUR FINAL	MODEL / CAT	No.		S	A50H-K/E3R/Z3
				DESIGN. ANY ORDER(S) MUST BE ACCOMPANIED BY OR	CUSTOMER		-		
				REFER TO THIS DRAWING. REX POWER MAGNETICS	PO #		-		R⊃⊂M
				RESERVES THE RIGHT TO CHANGE OR REVISE THESE	SWO #	-		QTY -	
				SPECIFICATIONS WITHOUT NOTICE	Prepared By	C.G.	Date	9/16/2020	REX POWER MAGNETICS
					Approved By		Date	-	

 \cap

__ . _. . _ _ _

FEATURES
- NEOPRENE ANTI-VIBRATION PADS INSTALLED BETWEEN CORE
& COIL AND ENCLOSURE BASE
- LUG FOR EARTH GROUNDING PROVIDED
- SEISMIC RATED FOR USA ZONE 4 AND CANADA ZONE 6
- CSA CERTIFIED (FILE # LR34493)
- UL LISTED (FILE # E108255)
- ISO 9001 QUALITY MANAGEMENT SYSTEM
- EFFICIENCY MEETS OR EXCEEDS:
CANADA: SOR/DORS/2018-201 (NRCan 2019)
CSA: CSA C802.2-18
USA: DOE 10 CFR PART 431:2016-01 (DOE 2016)



ENCLOSURE	
ENCLOSURE PART #	<u>E3R-6-W</u>
ENCLOSURE RATING	TYPE 3R (INDOOR/OUTDOOR)
CONSTRUCTION	VENTILATED
MATERIAL	STEEL
FINISH	POLYESTER POWDER COAT
COLOR	ANSI/ASA 61 (GREY)
MOUNTING	FLOOR